



OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, ALWAR

Lab/Tech/(Private)/2025-26/ 94

Dated : 18.05.26

EXAMINATION REPORT OF THE PRIVATE WATER SAMPLES

Issued To,

MAXFORD International School
Tatarpur Choraha, Khairthal Road
Tatarpur

District: Alwar
Block/City: Mundawar

Ref ID :	11	Lab Sample No. :	11
Reference : Your Letter No. :	0	Source :	Treated
Reference Dated :	13.05.26	Source Location :	Tatarpur Choraha Khairthal Road
Date of Receipt :	13.05.26	Habitation/Ward No. :	Tatarpur
Name of Sample Taker :	Mr. Dinesh Gahlot	Village/Colony/Town :	Tatarpur
Desig. of Sample Taker :	0	Gram Panchayat/City Area :	Tatarpur
GA-55 Book No. :	019774	Date of Collection :	13.05.26
GA-55 Receipt No. :	0064	Date of Examination :	13.05.26
Amount in Rs. :	297.00	Amount Deposited for :	Chem/Bact Testing of Water Sample
IS-10500:2012			
Test Parameters	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	Test Values of Samples
1 pH	6.5 to 8.5	No Relaxation	7.1
2 Turbidity (NTU)	5	15	Clear
3 Colour (Hazen Unit)	1	5	None
4 Odour	Unobjectionable	-	None
5 Total Alkalinity (as CaCO ₃) mg/L	200	600	30
6 Total Hardness (as CaCO ₃) mg/L	300	600	50
7 Calcium (as Ca++) mg/L	75	200	
8 Magnesium (as Mg++) mg/L	30	100	
9 Chloride (as Cl ⁻) mg/L	600	1000	30
10 Sulphate (as SO ₄ ⁻²) mg/L	200	400	0
11 Nitrates (as NO ₃) mg/L	45	No Relaxation	2
12 Fluoride (as F ⁻) mg/L	1.00	1.50	0.20
13 Total Dissolved Solids (TDS) mg/L	500	2000	94
14 Residual Chlorine (mg/L)	0.20	1.00	-
15 Total Coli Form/100 ml.	NIL/100 ml.	NIL/100 ml.	0
16 E-Coli/ 100 ml.	NIL/100 ml.	NIL/100 ml.	-

(1) The Sample was not collected by this Laboratory.

(2) Not valid for water quality Legal Cases.

Lab/Tech/(Private)/2025-26/

Copy to:

- 1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
- 2
- 3

Senior Chemist
PHED, Lab, Alwar

Dated:

Senior Chemist

Save Water Save Life

Safe Water is Life

e-Challan

Public Health Engineering Department
Government of Rajasthan

GRN: 0123415482



Payment Date: 13/05/2026 12:25:39

Office Name: Sr. Chemist,P.H.E.D.,Lab.Alwar
Location: ALWAR
Period: 01/04/2026-To-31/03/2027

S.No	Purpose/Budget Head Name	Amount (₹)
1	0215-02-800-01-00-RT	297.00

Commision(-):

0.00

Total/NetAmount:

297.00

Two Hundred Ninety Seven Rupees and Zero Paise Only

Payee Details:

Full Name: MAXFORD INTERNATIONAL SCHOOL	Tin/Actt.No./VehicleNo./Taxid :
Pan No.(If Applicable):	City(Pincode): ALWAR(301404)
Address:TATARPUR CHOURAHA KHAIRTHAL ROAD DIST-KHAIRTHAL TIJARA	Remarks:WATER REPORT FOR MAXFORD INTERNATIONAL SCHOOL KHAIRTHAL TIJARA

Payment Details:

Challan No. - 0

Bank:	State Bank Of India	Bank CIN No:	SBIN12341548213052026
Date:	13/05/2026 12:25:39	Refrence No:	IK0DQUEGN6

Computer generated copy on : 13/05/2026

Courtesy : <https://Egras.rajasthan.gov.in>